BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F0119

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

G1x-VM-E, Genesis Type A Indoor Temporal Beacon
(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Walter Kidde Portable Equipment Inc.
(Trading as Edwards, A Carrier Company)
8985 Town Center Parkway
Bradenton
FL. 34202
USA

and produced in the manufacturing plant(s):

Dongguan Sharp Motion Ltd
56 Weijian Road
Weijian Industrial Park
Chashan Dongguan
Guangdong
CHINA
Choose an item or hit spacebar.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-23:2010 - Visual Alarm Devices

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 21 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

P Halligan, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 21 October 2019
Date of Issue: 14 September 2022
Issue number 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

© BRE Global Assurance (Ireland) Limited, 2022

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0119

G1x-VM-E, Genesis Type A Indoor Temporal Beacon

Bases:

G1B-MP	White back box, G1 Series, plastic
G1RB-MP	Red back box, G1 Series, plastic
27193-16	White back box, Surface, metal
27193-11	Red back box, Surface, metal

The wall mounted VAD meets the requirements of EN 54-23:2010 for the following:

- Category (light pattern details):
- @15cd (W-3.0-2.8 or W-2.5-3.3)
- @30cd (W-3.0-4.6)
- @75cd (W-6.0-7.03)
- @110cd (W-6.0-6.0)
- Synchronization
- Flash rate 1Hz

Variants:

Key: x = Blank – White housing
= F – White housing with Fire Marking
= R – Red housing
= RF – Red housing with Fire Marking

P Halligan, Certification Engineer,
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 21 October 2019
Date of issue: 14 September 2022
Issue number: 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

© BRE Global Assurance (Ireland) Limited, 2022